



# WPDES PERMIT

*STATE OF WISCONSIN*  
*DEPARTMENT OF NATURAL RESOURCES*  
**PERMIT TO DISCHARGE UNDER THE  
WISCONSIN POLLUTANT DISCHARGE ELIMINATION SYSTEM**

**AFP ADVANCED FOOD PRODUCTS LLC**

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility  
located at

600 FIRST AVENUE WEST  
CLEAR LAKE, WISCONSIN  
to

CLEAR LAKE IN POLK COUNTY WITHIN THE UPPER WILLOW WATERSHED, AND THE  
GROUNDWATER OF THE ST. CROIX RIVER DRAINAGE BASIN VIA LANDSPREADING ON APPROVED  
SITES

in accordance with the effluent limitations, monitoring requirements and other conditions set  
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources  
For the Secretary

By

\_\_\_\_\_  
Kathy Bartilson  
Water Program Supervisor, St. Croix Basin, Northern Region

\_\_\_\_\_  
Date Permit Signed/Issued

**PERMIT TERM: EFFECTIVE DATE - November 01, 2006**

**EXPIRATION DATE - September 30, 2011**

## TABLE OF CONTENTS

<b>1 SURFACE WATER REQUIREMENTS.....</b>	<b>1</b>
1.1 SAMPLING POINT(S) .....	1
1.2 MONITORING REQUIREMENTS AND EFFLUENT LIMITATIONS .....	1
1.2.1 <i>Sampling Point (Outfall) 001 - NON-CONTACT COOLING WATER and 002- NON-CONTACT COOLING WATER..</i>	<i>1</i>
<b>2 LAND APPLICATION REQUIREMENTS .....</b>	<b>2</b>
2.1 SAMPLING POINT(S) .....	2
2.2 MONITORING REQUIREMENTS AND LIMITATIONS .....	2
2.2.1 <i>Sampling Point (Outfall) 003 - Groundwater - Landspreading.....</i>	<i>2</i>
<b>3 STANDARD REQUIREMENTS .....</b>	<b>4</b>
3.1 REPORTING AND MONITORING REQUIREMENTS .....	4
3.1.1 <i>Monitoring Results.....</i>	<i>4</i>
3.1.2 <i>Sampling and Testing Procedures .....</i>	<i>4</i>
3.1.3 <i>Recording of Results .....</i>	<i>4</i>
3.1.4 <i>Reporting of Monitoring Results.....</i>	<i>5</i>
3.1.5 <i>Records Retention.....</i>	<i>5</i>
3.1.6 <i>Other Information.....</i>	<i>5</i>
3.2 SYSTEM OPERATING REQUIREMENTS.....	5
3.2.1 <i>Noncompliance Notification .....</i>	<i>5</i>
3.2.2 <i>Unscheduled Bypassing .....</i>	<i>6</i>
3.2.3 <i>Scheduled Bypassing.....</i>	<i>6</i>
3.2.4 <i>Proper Operation and Maintenance.....</i>	<i>7</i>
3.2.5 <i>Spill Reporting.....</i>	<i>7</i>
3.2.6 <i>Planned Changes .....</i>	<i>7</i>
3.2.7 <i>Duty to Halt or Reduce Activity.....</i>	<i>7</i>
3.3 SURFACE WATER REQUIREMENTS .....	7
3.3.1 <i>Permittee-Determined Limit of Quantitation Incorporated into this Permit .....</i>	<i>7</i>
3.3.2 <i>Appropriate Formulas for Effluent Calculations.....</i>	<i>8</i>
3.3.3 <i>Visible Foam or Floating Solids .....</i>	<i>8</i>
3.4 LAND APPLICATION REQUIREMENTS .....	8
3.4.1 <i>Land Application Characteristic Report.....</i>	<i>8</i>
3.4.2 <i>Land Application Report.....</i>	<i>8</i>
3.4.3 <i>Other Methods of Disposal or Distribution Report .....</i>	<i>8</i>
3.4.4 <i>Land Application Site Approval.....</i>	<i>8</i>
3.4.5 <i>Operating Requirements/Management Plan.....</i>	<i>9</i>
3.4.6 <i>Chloride Requirements for Liquid Wastes and By-Product Solids .....</i>	<i>9</i>
3.4.7 <i>Nitrogen Requirements for Liquid Wastes and By-Product Solids and Sludges.....</i>	<i>9</i>
3.4.8 <i>Ponding.....</i>	<i>9</i>
3.4.9 <i>Runoff.....</i>	<i>9</i>
3.4.10 <i>Soil Incorporation Requirements .....</i>	<i>10</i>
3.4.11 <i>Additional Requirements from ch. NR 214, Wis. Adm. Code.....</i>	<i>10</i>
<b>4 SUMMARY OF REPORTS DUE .....</b>	<b>11</b>

# 1 Surface Water Requirements

## 1.1 Sampling Point(s)

The discharge(s) shall be limited to the waste type(s) designated for the listed sampling point(s).

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
001	Representative samples shall be taken at the V-notch weir in the factory basement.
002	Representative samples shall be taken at the Parshall Flume in the sampling manhole in the factory.

## 1.2 Monitoring Requirements and Effluent Limitations

The permittee shall comply with the following monitoring requirements and limitations.

### 1.2.1 Sampling Point (Outfall) 001 - NON-CONTACT COOLING WATER and 002- NON-CONTACT COOLING WATER

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Monthly	Estimated	
Temperature	Daily Max	89 deg F	Monthly	Grab	
BOD <sub>5</sub> , Total	Daily Max	10 mg/L	Monthly	Grab	

#### 1.2.1.1 Non-contact Cooling Water

The discharge shall be limited solely to non-contact cooling water, free from process water and other wastewater discharges. Any proposed additions of water treatment additives must be approved by the Department prior to use.

## 2 Land Application Requirements

### 2.1 Sampling Point(s)

The discharge(s) shall be limited to land application of the waste type(s) designated for the listed sampling point(s) on Department approved land spreading sites or by hauling to another facility.

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
003	Representative samples shall be taken from the storage tanks or from the spreading truck tank as it is being loaded for landspreading.

### 2.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

#### 2.2.1 Sampling Point (Outfall) 003 - Groundwater - Landspreading

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate	Daily Max	20,000 gpd	Daily	Total Daily	
BOD <sub>5</sub> , Total		mg/L	Quarterly	Grab	
Nitrogen, Total Kjeldahl		mg/L	Quarterly	Grab	
Chloride		mg/L	Quarterly	Grab	
Phosphorus, Total		mg/L	Quarterly	Grab	
Potassium, Total Recoverable		mg/L	Quarterly	Grab	

##### 2.2.1.1 Flow Limit

The monthly average flow to landspreading sites is calculated by dividing the total discharge volume for the month by the total number of days in the month. The average of the daily flow volumes shall not exceed 20,000 gallons per day on a monthly average.

<b>Daily Log – Monitoring Requirements and Limitations</b>				
All discharge and monitoring activity shall be documented on log sheets. Originals of the log sheets shall be kept by the permittee as described under “Records Retention” in the Standard Requirements section, and if requested, made available to the Department.				
<b>Parameters</b>	<b>Limit</b>	<b>Units</b>	<b>Sample Frequency</b>	<b>Sample Type</b>
DNR Site Number(s)	-	Number	Daily	Log
Acres Applied	-	Acres	Daily	Log
Frozen Site Maximum Daily Loading Volume	6,800	Gal/Acre/Day	Daily	Calculated
Unfrozen Site Maximum Daily Loading Volume	13,500	Gal/Acre/Day	Daily	Calculated
Weekly Loading Volume	See NR 214 - Tbl 3	Inches/Week	Weekly	Calculated

<b>Annual Report – Monitoring Requirements and Limitations</b>				
The Annual Report is due by January 31 <sup>st</sup> of each year for the previous calendar year.				
<b>Parameters</b>	<b>Limit</b>	<b>Units</b>	<b>Reporting Frequency</b>	<b>Sample Type</b>
DNR Site Number(s)	-	Number	-	-
Acres Land Applied	-	Acres	Annual	-
Total Volume Per Site	-	Gallons	Annual	Total Annual
Total Kjeldahl Nitrogen per Site	165, or alternate approved in writing	Pounds/Acre/Year	Annual	Calculated

### 2.2.1.2 Annual Site Nitrogen Loading

For details on nitrogen loading requirements, including approval of an alternate nitrogen pounds/acre/year site loading, see the “Nitrogen Requirements for Liquid Wastes, By-Product Solids and Sludges” paragraph in the Standard Requirements section of this permit.

### 3 Standard Requirements

**NR 205, Wisconsin Administrative Code (Conditions for Industrial Dischargers):** The conditions in ss. NR 205.07(1) and NR 205.07(3), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(3).

#### 3.1 Reporting and Monitoring Requirements

##### 3.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report Form in either electronic or paper format. The report form may require reporting of any or all of the information specified below under 'Recording of Results'. This report form is to be returned to the Department no later than the date indicated on the form. When submitting a paper Discharge Monitoring Report form, the original and one copy of the Wastewater Discharge Monitoring Report Form shall be submitted to the return address printed on the form. A copy of the Wastewater Discharge Monitoring Report Form shall be retained by the permittee.

Electronic discharge monitoring reports may be submitted instead of paper reports. Prior to submitting any electronic discharge monitoring reports, the permittee shall obtain a Trading Partner Agreement that is signed by both the permittee and the Department. The Trading Partner Agreement becomes effective upon the date of signature by both parties and continues in effect until modified or terminated. An Electronic Discharge Monitoring Report Certification sheet shall also be signed and submitted with each electronic Discharge Monitoring Report submittal. This certification sheet, which is not part of the electronic report form, shall be signed by a principal executive officer, a ranking elected official or other duly authorized representative and shall be mailed to the Department at the time of submittal of the electronic Discharge Monitoring Report. The certification sheet certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report Form.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

Monitoring reports shall be signed by a principal executive officer, a ranking elected official, or other duly authorized representative.

##### 3.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code and shall be performed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sample collection and analysis shall be performed in accordance with ch. NR 140, Wis. Adm. Code. The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation. If the required level cannot be met by any of the methods available in NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

##### 3.1.3 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- the date, exact place, method and time of sampling or measurements;
- the individual who performed the sampling or measurements;
- the date the analysis was performed;
- the individual who performed the analysis;
- the analytical techniques or methods used; and
- the results of the analysis.

### **3.1.4 Reporting of Monitoring Results**

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a 0 (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.

### **3.1.5 Records Retention**

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application, except for sludge management forms and records, which shall be kept for a period of at least 5 years.

### **3.1.6 Other Information**

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

## **3.2 System Operating Requirements**

### **3.2.1 Noncompliance Notification**

- The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance;
  - any noncompliance which may endanger health or the environment;
  - any violation of an effluent limitation resulting from an unanticipated bypass;
  - any violation of an effluent limitation resulting from an upset; and
  - any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit.
- A written report describing the noncompliance shall also be submitted to the Department's regional office within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the

Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

- The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

NOTE: Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources **immediately** of any discharge not authorized by the permit. The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at **1-800-943-0003**.

### 3.2.2 Unscheduled Bypassing

Any unscheduled bypass or overflow of wastewater at the treatment works or from the collection system is prohibited, and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats., unless:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
- The permittee notified the Department as required in this Section.

Whenever there is an unscheduled bypass or overflow occurrence at the treatment works or from the collection system, the permittee shall notify the Department within 24 hours of initiation of the bypass or overflow occurrence by telephoning the wastewater staff in the regional office as soon as reasonably possible (FAX, email or voice mail, if staff are unavailable).

In addition, the permittee shall within 5 days of conclusion of the bypass or overflow occurrence report the following information to the Department in writing:

- Reason the bypass or overflow occurred, or explanation of other contributing circumstances that resulted in the overflow event. If the overflow or bypass is associated with wet weather, provide data on the amount and duration of the rainfall or snow melt for each separate event.
- Date the bypass or overflow occurred.
- Location where the bypass or overflow occurred.
- Duration of the bypass or overflow and estimated wastewater volume discharged.
- Steps taken or the proposed corrective action planned to prevent similar future occurrences.
- Any other information the permittee believes is relevant.

### 3.2.3 Scheduled Bypassing

Any construction or normal maintenance which results in a bypass of wastewater from a treatment system is prohibited unless authorized by the Department in writing. If the Department determines that there is significant



public interest in the proposed action, the Department may schedule a public hearing or notice a proposal to approve the bypass. Each request shall specify the following minimum information:

- proposed date of bypass;
- estimated duration of the bypass;
- estimated volume of the bypass;
- alternatives to bypassing; and
- measures to mitigate environmental harm caused by the bypass.

### **3.2.4 Proper Operation and Maintenance**

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. The wastewater treatment facility shall be under the direct supervision of a state certified operator as required in s. NR 108.06(2), Wis. Adm. Code. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

### **3.2.5 Spill Reporting**

The permittee shall notify the Department in accordance with ch. NR 706 (formerly NR 158), Wis. Adm. Code, in the event that a spill or accidental release of any material or substance results in the discharge of pollutants to the waters of the state at a rate or concentration greater than the effluent limitations established in this permit, or the spill or accidental release of the material is unregulated in this permit, unless the spill or release of pollutants has been reported to the Department in accordance with s. NR 205.07 (1)(s), Wis. Adm. Code.

### **3.2.6 Planned Changes**

In accordance with ss. 283.31(4)(b) and 283.59, Stats., the permittee shall report to the Department any facility expansion, production increase or process modifications which will result in new, different or increased discharges of pollutants. The report shall either be a new permit application, or if the new discharge will not violate the effluent limitations of this permit, a written notice of the new, different or increased discharge. The notice shall contain a description of the new activities, an estimate of the new, different or increased discharge of pollutants and a description of the effect of the new or increased discharge on existing waste treatment facilities. Following receipt of this report, the Department may modify this permit to specify and limit any pollutants not previously regulated in the permit.

### **3.2.7 Duty to Halt or Reduce Activity**

Upon failure or impairment of treatment facility operation, the permittee shall, to the extent necessary to maintain compliance with its permit, curtail production or wastewater discharges or both until the treatment facility operations are restored or an alternative method of treatment is provided.

## **3.3 Surface Water Requirements**

### **3.3.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit**

For pollutants with water quality-based effluent limits below the Limit of Quantitation (LOQ) in this permit, the LOQ calculated by the permittee and reported on the Discharge Monitoring Reports (DMRs) is incorporated by reference into this permit. The LOQ shall be reported on the DMRs, shall be the lowest quantifiable level practicable, and shall

be no greater than the minimum level (ML) specified in or approved under 40 CFR Part 136 for the pollutant at the time this permit was issued, unless this permit specifies a higher LOQ.

### 3.3.2 Appropriate Formulas for Effluent Calculations

The permittee shall use the following formulas for calculating effluent results to determine compliance with average limits and mass limits:

**Weekly/Monthly average concentration** = the sum of all daily results for that week/month, divided by the number of results during that time period.

**Weekly Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the week.

**Monthly Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the month.

### 3.3.3 Visible Foam or Floating Solids

There shall be no discharge of floating solids or visible foam in other than trace amounts.

## 3.4 Land Application Requirements

### 3.4.1 Land Application Characteristic Report

The analytical results from testing of liquid wastes, by-product solids and sludges that are land applied shall be reported annually on the Characteristic Form 3400-49. The report shall be submitted by January 31 following each year of analysis.

The permittee shall use the following convention when reporting sludge monitoring results: Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 1.0 mg/kg, report the pollutant concentration as < 1.0 mg/kg .

All sludge results shall be reported on a dry weight basis.

### 3.4.2 Land Application Report

The annual totals for the land application loadings of liquid wastes, by-product solids and sludges to field spreading sites shall be submitted on the Land Application Report Form 3400-55 by January 31, following each year waste is land applied.

### 3.4.3 Other Methods of Disposal or Distribution Report

The permittee shall submit Report Form 3400-52 by January 31, following each year waste is hauled to another facility, landfilled, incinerated, or stored in a manure pit.

### 3.4.4 Land Application Site Approval

The permittee is authorized to landspread permitted liquid wastes, by-product solids and sludges on sites approved in writing by the Department in accordance with ss. NR 214.17(2) and 214.18(2), Wis. Adm. Code. Any site use restrictions or granting of case-by-case exceptions shall be identified in the approval letter. If the permittee wishes to have approval for additional sites, application shall be made using Land Application Site Request Form 3400-053.

Complete information shall be submitted about each site, including location maps and soil maps, any soil analyses results and other information showing that the site complies with all application requirements and permit conditions. Spreading on a site may commence upon receipt of Department approval. If an existing spreading site is found by the Department to be environmentally unacceptable, a written notice will be issued to withdraw approval of that site.

### 3.4.5 Operating Requirements/Management Plan

All land application sites used for treatment of liquid wastes, by-product solids and sludges shall be operated in accordance with a Department approved management plan. The management plan shall be consistent with the requirements of this permit, ss. NR 214.17 (3) and (6), and NR 214.18 (3) and (6), Wis. Adm. Code. If operational changes are needed, the land application management plan shall be amended by submitting a written request to the Department for approval. A land application management plan shall be submitted for approval at least 60 days prior to land application.

### 3.4.6 Chloride Requirements for Liquid Wastes and By-Product Solids

The total pounds of chloride applied shall be limited to 340 pounds per acre per 2 year period. Calculate the chloride loading as follows:

$$\text{Wet Weight Solids: } \frac{\text{lbs of solids} \times \% \text{solids} \times \% \text{chloride}}{\text{acres land applied} \times 100 \times 100} = \text{lbs chloride/acre}$$

$$\text{Liquid: } \frac{\text{mg/L chloride} \times (\text{millions of gallons}) \times 8.34}{\text{acres land applied}} = \text{lbs chloride/acre}$$

### 3.4.7 Nitrogen Requirements for Liquid Wastes and By-Product Solids and Sludges

NR 214.17(4) and NR 214.18(4) Wis. Adm. Code specify that the total pounds of nitrogen land applied per acre per year shall be limited to the nitrogen needs of the cover crop minus any other nitrogen added to the land application site, including fertilizer or manure. Nitrogen applied can be calculated on the basis of plant available nitrogen, as long as the release of nitrogen from the organic material is credited to future years. This permit requires that the Total Kjeldahl Nitrogen calendar year application amount shall not exceed 165 pounds per acre per year, except when alternate numerical nitrogen loading limits (consistent with the above sections of NR 214) are approved in writing via the Department's land application management plan approval. Calculate nitrogen loading as follows ("TKN" represents "Total Kjeldahl Nitrogen"):

$$\text{Wet Weight Solids and Sludges: } \frac{\text{lbs of solids} \times \% \text{solids} \times \% \text{TKN}}{\text{acres land applied} \times 100 \times 100} = \text{lbs TKN/acre}$$

$$\text{Liquid: } \frac{\text{mg/L TKN} \times (\text{millions of gallons}) \times 8.34}{\text{acres land applied}} = \text{lbs TKN/acre}$$

### 3.4.8 Ponding

The volume of liquid wastes land applied shall be limited to prevent ponding, except for temporary conditions following rainfall events. If ponding occurs all land application shall cease immediately. The permittee shall land apply only the liquid wastes that are permitted.

### 3.4.9 Runoff

The volume of liquid wastes land applied shall be limited to prevent runoff. If runoff occurs all land application shall cease immediately. The permittee shall land apply only the liquid wastes that are permitted.

### **3.4.10 Soil Incorporation Requirements**

- **Liquid Sludge Requirements:** The Department may require that liquid sludge be incorporated into the soil on specific land application sites when necessary to prevent surface runoff or objectionable odors. Requirements and procedures for incorporation of liquid sludge, when such incorporation may be necessary, shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.
- **Cake Sludge Requirements:** After land application, cake sludge shall be incorporated into the soil. The timing of such incorporation and other related requirements and procedures shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.
- **Liquid Wastewater Requirements:** The Department may require that liquid wastewater be incorporated or injected into the soil on specific land application sites when necessary to prevent surface runoff or objectionable odors. Requirements and procedures for injection or incorporation of liquid wastewater, when such injection or incorporation is necessary, shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.
- **By-Product Solids Requirements:** The Department may limit the volume of by-products solids that are landspread on a specific site when necessary to prevent surface runoff or leaching of contaminants to groundwater and objectionable odors. By-product solids shall, after application, be plowed, disced, or otherwise incorporated into the soil. Requirements and procedures for the incorporation of byproduct solids into the soil shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.

### **3.4.11 Additional Requirements from ch. NR 214, Wis. Adm. Code**

The requirements of s. NR 214.17 (4)(c) [pathogen prohibition for human consumption crop fields], (4)(d)1 [no adverse soil effects], (4)(d)10 [allowable whey spreading rates], and (4)(e)1-3 [by-product solids spreading within agricultural practices and not cause contamination] for landspreading of liquid wastes and by product solids and s. NR 214.18 (4)(b),(d)-(h) [application, nutrient, pH, metals, and PCB limitations] for sludge spreading systems are included by reference in this permit. The permittee shall comply with these requirements.

## 4 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
Characteristic Form 3400-49	January 31 following each year of analysis	8
Land Application Report Form 3400-55	January 31, following each year waste is land applied	8
Report Form 3400-52	by January 31, following each year waste is hauled to another facility, landfilled, incinerated, or stored in a manure pit	8
Wastewater Discharge Monitoring Report Form	no later than the date indicated on the form	4

All submittals required by this permit shall be submitted to the Northern Region - Cumberland, 1341 2nd Avenue, P.O. Box 397, Cumberland, WI 54829, except as follows. Report forms shall be submitted to the address printed on the report form. Any facility plans or plans and specifications for municipal, industrial pretreatment and non industrial wastewater systems shall be submitted to the Regional Plan Reviewer (as designated at [www.dnr.state.wi.us/org/water/wm/consultant.htm](http://www.dnr.state.wi.us/org/water/wm/consultant.htm)). Any construction plans and specifications for industrial wastewater systems shall be submitted to the Bureau of Watershed Management, P.O. Box 7921, Madison, WI 53707-7921.